



# વડવગર નગરપાલિકા

હરબાર રોડ, વડવગર-૩૮૪૩૫૫  
જી.મહેસાણા


Date: 31/1/2015

## Performance - Certificate

This is to certify that MBH make Submerged centrifugal pumpset supplied to Vadnagar Nagarpalika with following data is running successfully till date.

Duty point of pump :- 2500 L.P.M , 35 mtrs head,1450 rpm, 35 HP  
Qty :- 02 Nos.  
Sr No. :- 13090073, 13090074  
Duty point of pump :- 3500 L.P.M , 35 mtrs head,1450 rpm, 40 HP  
Qty :- 04 Nos  
Sr No. :- 13090067, 13090068, 13090069  
Duty point of pump :- 2100 L.P.M , 55 mtrs head,1450 rpm, 45 HP  
Qty :- 03 Nos  
Sr No. :- 13090070, 13090071, 13090072

Performance of above pumps is satisfactory.

  
Municipal Engineer  
Vadnagar Nagar Palika





# ગુજરાત પાણી પુરવઠા અને ગટર વ્યવસ્થા બોર્ડ

નાયબ કાર્યપાલક ઈજનેરશ્રીની કચેરી જાહેર આરોગ્ય સુખાકારી પેટા વિભાગ,  
બિન્દુસરીવર રોડ રેલ્વે કાટક પાસે સિદ્ધપુર જિલ્લો-પાટણ

ફોન (કચેરી) ૦૨૭૬૭૨૨૫૩૩૧ (અધિકારી) ૯૯૭૮૪૦૬૭૫૬ email - gwsdeesidhco@gmail.com

25/01/2015

## Performance – Certificate

This is to certify that M/S H make Submerged centrifugal pumpset supplied to Siddhpur Nagarpalika with following data is running successfully till date.

Duty point of pump :- 2500 L.P.M , 36 mtrs head, 1450 rpm, 35 HP

Qty :- 05 Nos.

Sr No. :- 13110092, 13110093, 13110094, 13110095, 13110096

Duty point of pump :- 3500 L.P.M , 35 mtrs head, 1450 rpm, 40 HP

Qty :- 04 Nos

Sr No. :- 13110088, 13110089, 13110090, 13110091

Performance of above pumps is satisfactory.

DEPUTY EXECUTIVE ENGINEER  
P.H.S. SUB DIVISION  
SIDDHPUR